

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3226-0935:114 Page 1 of 1

CATEGORY: Ceiling Dampers

LISTEE: Nailor Industries, 4714 Winfield Rd, Houston TX 77039
Contact: John Young (281) 590-1172 FAX (281) 590-3086

DESIGN: Models 0755, 0756, 0757, CRD5 and CRD6 ceiling dampers for use in approved floor-ceiling and roof/ceiling designs. Ceiling dampers function as a heat barrier in air handling penetrations through fire resistive ceilings and are intended to maintain the fire resistive integrity of the ceiling. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as ceiling dampers for use in fire resistive floor-ceiling and roof/ceiling assemblies, with an unrestrained assembly rating of 1 hour, UL Design Nos. L550/562 and P531/538. Refer to listee's Installation Instruction Manual and UL Fire Resistance Directory for details.

NOTE: Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for listed leakage dampers.

05-10-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 13, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager